



PORT OF OAKLAND

OAKLAND INTERNATIONAL AIRPORT HANGAR INSPECTION CHECKLIST

- Stored aircraft must be airworthy, properly registered to the hangar owner, and properly insured.
- If non-airworthy, aircraft must show significant signs of progress every 90 days.
- No more than one vehicle in addition to the aircraft is to be stored in a single hangar.
- No storage of household items or recreational vehicles (i.e. boats, motorhomes, trailers or campers) that could be stored in commercial storage facilities.
- No long-term storage of derelict aircraft or parts; storage of items or activities prohibited by local or state law.
- Storage of other items will not impede aircraft ingress and egress.
- Exit path is clear of obstructions.
- Fire extinguisher that is not expired and is accessible.
- Combustible material is stored properly and not stock piled in excess.
- No more than 5 gallons of flammable liquids stored without proper permit.
- No spraying, painting or dipping utilizing flammable liquids without proper permit.
- Extension cords must not be used as a permanent source of wiring.
- No excessive use of extension cords, appliances, outlets, etc.
- Junction boxes must be covered and maintained properly.
- Portable electric heater must be directly plugged into a permanent receptacle.
- Hangar doors in proper working condition and have not been altered/modified to affect functionality.

Hangar Location:	Hangar #:
Inspected By:	Violations Found: Yes / No
Inspection Date:	Correction Date:



One Airport Drive ■ Box 45 ■ Oakland, California 94621

Telephone: (510) 627-1100 ■ Facsimile: (510) 627-1826 ■ Web Page: www.oaklandairport.com